

TITLE 14 HOUSING AND CONSTRUCTION
CHAPTER 8 PLUMBING CODES
PART 2 2024 NEW MEXICO PLUMBING CODE

14.8.2.1 ISSUING AGENCY: Construction Industries Division (CID) of the Regulation and Licensing Department.

[14.8.2.1 NMAC - Rp, 14.8.2.1 NMAC, 08/01/2026]

14.8.2.2 SCOPE: This rule applies to all contracting work performed in New Mexico on or after August 1, 2026, that is subject to the jurisdiction of CID, unless performed pursuant to a permit for which an application was received by CID before that date.

[14.8.2.2 NMAC - Rp, 14.8.2.2 NMAC, 08/01/2026]

14.8.2.3 STATUTORY AUTHORITY: Section 60-13-9, 60-13-33, 60-13-44, 60-13-45, 60-13-46 and 60-13-47 NMSA 1978.

[14.8.2.3 NMAC - Rp, 14.8.2.3 NMAC, 08/01/2026]

14.8.2.4 DURATION: Permanent.

[14.8.2.4 NMAC - Rp, 14.8.2.4 NMAC, 08/01/2026]

14.8.2.5 EFFECTIVE DATE: August 1, 2026, unless a later date is cited at the end of a section. From the date of publication of this rule in the New Mexico register, until January 1, 2027, permits may be issued under either the previously adopted rule, or this rule. After January 1, 2027, permits may be issued only under this rule.

[14.8.2.5 NMAC - Rp, 14.8.2.5 NMAC, 08/01/2026]

14.8.2.6 OBJECTIVE: The purpose of this rule is to establish minimum standards for the installation, alteration, repair, relocation, replacement, addition to, use, or maintenance of all plumbing, as defined in Section 60-12-32 NMSA 1978, in New Mexico.

[14.8.2.6 NMAC - Rp, 14.8.2.6 NMAC, 08/01/2026]

14.8.2.7 DEFINITIONS: See 14.5.1 NMAC, General Provisions and Chapter 2 of the 2024 Uniform Plumbing Code (UPC) as amended in 14.8.2.10 NMAC.

[14.8.2.7 NMAC - Rp, 14.8.2.7 NMAC, 08/01/2026]

14.8.2.8 ADOPTION OF THE 2024 UNIFORM PLUMBING CODE:

- A. This rule adopts by reference the 2024 UPC and all appendices, as amended by this rule.
- B. In this rule, each provision is numbered to correspond with the numbering of the 2024 UPC.
- C. This rule shall apply in conjunction with the provisions of all applicable New Mexico construction codes, laws and standards.

[14.8.2.8 NMAC - Rp, 14.8.2.8 NMAC, 08/01/2026]

14.8.2.9 CHAPTER 1 ADMINISTRATION: See this chapter of the UPC except as provided below.

- A. **Section 101.0 General.** See this section of the UPC except as provided below.

(1) **Section 101.1 Title.** Delete this section of the UPC and substitute with the following:
This code shall be known as 14.8.2 NMAC, the 2024 New Mexico Plumbing Code (NMPC).

(2) **Section 101.2 Scope.** Delete this section of the UPC and see 14.8.2.2 NMAC.

(3) **Section 101.3 Purpose.** Delete this section of the UPC and see 14.8.2.6 NMAC.

(4) **Section 101.4 Unconstitutional.** Delete this section of the UPC and see the Construction Industries Licensing Act (CILA) and its rules.

(5) **Section 101.5 Validity.** Delete this section of the UPC and see CILA and its rules.

- B. **Section 102.0 Applicability.** See this section of the UPC except as provided below.

(1) **Section 102.1 Conflicts between codes.** Delete this section of the UPC and see 60-13-44 NMSA 1978 and 14.5.1 NMAC.

- (2) **Section 102.2 Existing installations.** See this section of the UPC and 60-13-44 NMSA 1978 and 14.7.7 NMAC.
- (3) **Section 102.3 Maintenance.** See this section of the UPC and 14.5.2 and 14.6.6 NMAC.
- (4) **Section 102.8 Appendices.** Delete this section of the UPC and see 14.8.2.30 NMAC.
- C. **Section 103.0 Duties and Powers of the Authority Having Jurisdiction.** See this section of the UPC except as provided below.
 - (1) **Section 103.1 General.** Delete this section of the UPC and see CILA and 14.8.2.10 NMAC.
 - (2) **Section 103.2 Liability.** Delete this section of the UPC and see 60-13-26 NMSA 1978.
 - (3) **Section 103.3 Applications and permits.** Delete this section of the UPC and see 14.5.2 NMAC.
 - (4) **Section 103.4 Right of entry.** Delete this section of the UPC and see 60-13-42 NMSA 1978.
- D. **Section 104.0 Permits.** See this section of the UPC except as provided below.
 - (1) **Section 104.1 Permits required.** Delete this section of the UPC and see 14.5.2 NMAC.
 - (2) **Section 104.2 Exempt work.** See this section of the UPC and 60-13-45 NMSA 1978.
 - (3) **Section 104.3 Application for permit.** Delete this section of the UPC and see 14.5.2 NMAC.
 - (4) **Section 104.4 Permit issuance.** Delete this section of the UPC and see 14.5.2 NMAC.
 - (5) **Section 104.5 Fees.** Delete this section of the UPC and see 14.5.5 NMAC.
- E. **Section 105.0 Inspections and Testing.** Delete these sections and see 14.5.3 NMAC.
- F. **Section 106.0 Violations and Penalties.** Delete this section of the UPC and see 60-13-1 through 60-13-59 NMSA 1978, 14.5.3 and 14.5.8 NMAC.
- G. **Section 107.0 Board of Appeals.** Delete this section of UPC and see 14.5.1 NMAC.
- H. **Table 104.5 Plumbing Permit Fees.** Delete this table from the UPC and see 14.5.5 NMAC. [14.8.2.9 NMAC - Rp, 14.8.2.9 NMAC, 08/01/2026]

14.8.2.10 CHAPTER 2 DEFINITIONS: See this chapter of the UPC except as provided below.

- A. **Section 203.0 Authority Having Jurisdiction.** Delete this definition and substitute with the following: The authority having jurisdiction is the CID and the mechanical-plumbing trade bureau chief for adoption, enactment, interpretation and enforcement of the state adopted plumbing code as the minimum requirement for the state of New Mexico.
- B. **Section 204.0 Bonding Jumper.** Delete this definition from the UPC and see 14.10.4 NMAC.
- C. **Section 205.0.** See this section of the UPC except as provided below.
 - (1) **Category 1.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (2) **Category 2.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (3) **Category 3.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (4) **Category 3 Vacuum system.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (5) **Category 4.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (6) **Confined space.** Delete this definition of the UPC and substitute with the following: A room or space having a volume less than 50 cubic feet per 1000 British thermal units per hour (Btu/hr) (4.83 m³/kW) of the aggregate input rating of all fuel-burning appliances installed in that space.
 - (7) **Critical care area.** Delete this definition of the UPC and see 14.8.4 NMAC.
- D. **Section 206.0 Department Having Jurisdiction.** Delete this section of the UPC.
- E. **Section 209.0.** See this section of the UPC except as provided below. **General anesthesia and levels of sedation/analgesia.** Delete this section of the UPC and see 14.8.4 NMAC.
- F. **Section 214.0.** See this section of the UPC except as provided below.
 - (1) **Listed (third party certified).** See this definition in the UPC and add the following provision at the end of the definition: A manufacturer may select an independent certification organization of its choice to certify its products, provided that the certification organization has been accredited by the American national standards institute (ANSI), or another certification organization that CID has approved in writing.
 - (2) **Listing agency.** See this definition in the UPC and 60-13-44 NMSA 1978.
- G. **Section 215.0.** See this section of the UPC except as provided below.
 - (1) **Medical air.** Delete this definition in the UPC and see 14.8.4 NMAC.
 - (2) **Medical gas.** Delete this definition in the UPC and see 14.8.4 NMAC.
 - (3) **Medical-surgical vacuum.** Delete this definition in the UPC and see 14.8.4 NMAC.

- (4) **Medical-surgical vacuum system.** Delete this definition in the UPC and see 14.8.4 NMAC.
- H. **Section 216.0.** See this section of the UPC except as provided below. **Nitrogen NF.** Delete this definition of the UPC and see 14.8.4 NMAC.
- I. **Section 218.0.** See this section of the UPC except as provided below.
- (1) **Patient care space.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (2) **Patient medical gas.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (3) **Proportioning system for medical air USP.** Delete this definition of the UPC and see 14.8.4 NMAC.
- J. **Section 221.0.** See this section of the UPC except as provided below.
- (1) **Station inlet.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (2) **Station outlet.** Delete this definition of the UPC and see 14.8.4 NMAC.
- K. **Section 224.0.** See this section of the UPC except as provided below.
- (1) **Vacuum system-level 1.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (2) **Valve, riser.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (3) **Valve, service.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (4) **Valve, source.** Delete this definition of the UPC and see 14.8.4 NMAC.
 - (5) **Valve, zone.** Delete this definition of the UPC and see 14.8.4 NMAC.

[14.8.2.10 NMAC - Rp, 14.8.2.10 NMAC, 08/01/2026]

14.8.2.11 CHAPTER 3 GENERAL REGULATIONS: See this chapter of the UPC except as provided below.

- A. **Section 301.3 Alternate Materials and Methods of Construction Equivalency.** Delete this section of the UPC and see 14.5.1 NMAC.
- B. **Section 301.5 Alternative Engineered Design.** See this section of the UPC except as provided below.
- (1) **Section 301.5.1 Permit application.** Delete this section of the UPC and see 14.5.2 NMAC.
 - (2) **Section 301.5.2 Technical data.** See this section of the UPC and 14.5.2 NMAC.
 - (3) **Section 301.5.3 Design documents.** See this section of the UPC and 14.5.2 NMAC.
 - (4) **Section 301.5.4 Design approval.** Delete this section of the UPC and see 14.5.2 NMAC.
 - (5) **Section 301.5.5 Design review.** Delete this section of the UPC and see 14.5.2 NMAC.
 - (6) **Section 301.5.6 Inspection and testing.** Delete this section of the UPC and see 14.5.2 and 14.5.3 NMAC.
- C. **Section 310.9 Female Plastic Connections.** See this section of the UPC and add the following to the end of the first sentence: “unless permitted by manufacturer.”.
- D. **Section 319.0 Medical Gas and Vacuum Systems.** Delete this section of the UPC and see 14.8.4 NMAC.

[14.8.2.11 NMAC - Rp, 14.8.2.11 NMAC, 08/01/2026]

14.8.2.12 CHAPTER 4 PLUMBING FIXTURES AND FIXTURE FITTINGS: See this chapter of the UPC except as provided below.

- A. **Section 403.0 Accessible Plumbing Facilities.** See this section of the UPC except as provided below.
- (1) **Section 403.1 General.** Delete this section of the UPC and see 14.7.2 NMAC.
 - (2) **Section 403.2 Fixtures and fixture fittings for persons with disabilities.** Delete this section of the UPC and see 14.7.2 NMAC.
- B. **Section 405.0 Prohibited Fixtures.** See this section of the UPC except as provided below.
- Section 405.3 Miscellaneous fixtures.** See this section of the UPC and add the following sentence to the end of the section: The authority having jurisdiction reserves the right to require the contractor to install water and drain lines to be used for installation of a flush-type toilet should the chemical-dry toilet fail.
- C. **Section 415.0 Drinking Fountains.** See this section of the UPC except as provided below.
- Section 415.2 Drinking fountain alternatives.** Delete this section of the UPC and see 14.7.2 NMAC.
- D. **Section 422.0 Minimum Number of Required Fixtures.** Delete this section of the UPC and see 14.7.2 NMAC.
- E. **Table 422.1 Minimum Plumbing Facilities.** Delete this table of the UPC and see 14.7.2 NMAC.

[14.8.2.12 NMAC - Rp, 14.8.2.12 NMAC, 08/01/2026]

14.8.2.13 CHAPTER 5 WATER HEATERS: See this chapter of the UPC except as provided below.

A. Section 501.0 General. See this section of the UPC except as provided below. **Section 501.1 Applicability.** See this section of the UPC except delete the following sentence: The minimum capacity for water heaters shall be in accordance with the first hour rating listed in Table 501.1(2).

B. Section 506.4 Outdoor Combustion Air. See this section of the UPC except as provided below.

(1) Section 506.4.1 Two permanent openings method. See this section of the UPC except add the following to the beginning of the section: Two permanent openings are required for LP gas fuel-burning appliances. Natural gas fuel-burning appliances are permitted to utilize this method.

(2) Section 506.4.2 One permanent opening method. See this section of the UPC except add the following to the beginning of the section: One permanent opening shall not be permitted for LP gas fuel-burning appliances. Natural gas fuel-burning appliances are permitted to utilize this method.

C. Section 507.5 Drainage Pan. Delete this section of the UPC and substitute with the following: Where a water heater is located in an attic, in or on an attic assembly, floor-ceiling assembly, floor-subfloor assembly or where structural damage may result from a leaking water heater, a watertight pan of corrosion resistant material shall be installed beneath the water heater in accordance with the following: (1) The drainage pan shall be provided with not less than $\frac{3}{4}$ of an inch (20mm) diameter drain to an approved location. The terminating end of the drainpipe shall be readily visible. (2) The drainage pan shall be not less than 1-1/2 inches (38mm) in depth. (3) Discharge from a relief valve into a drainage pan shall be prohibited.

D. Section 508.3 Appliances on roofs. See this section of the UPC except as provided below.

Section 508.3.1 Access. See this section of the UPC and add the following to the end of the section: **Exception:** Buildings designated as R-3 occupancies.

E. Section 510.1 Additional Requirements to Single Appliance Vent. See this section of the UPC except as provided below. **Section 510.1.10 Chimney and vent locations.** See this section of the UPC except delete the following language: Where vents extend outdoors above the roof more than 5 feet (1524mm) higher than required by table 509.6.1, and where vents terminate in accordance with section 509.6.1(1)(b), the outdoor portion of the vent shall be enclosed as required by this paragraph for vents not considered to be exposed to the outdoors, or such venting system shall be engineered.

F. Section 510.2 Additional Requirements to Multiple-Appliance Vent. See this section of the UPC except as provided below. **Section 510.2.20 Chimneys and vents.** See this chapter of the UPC except delete the following language: Where vents extend outdoors above the roof more than 5 feet (1524mm) higher than required by Table 509.6.1, and where vents terminate in accordance with Section 509.6.1(1)(b), the outdoor portion of the vent shall be enclosed as required by this paragraph for vents not considered to be exposed to the outdoors or such venting shall be engineered.

[14.8.2.13 NMAC - Rp, 14.8.2.13 NMAC, 08/01/2026]

14.8.2.14 [RESERVED]

14.8.2.15 CHAPTER 6 WATER SUPPLY AND DISTRIBUTION: See this chapter of the UPC except as provided below.

A. Section 608.2 Excessive Water Pressure. See this section of the UPC except delete the last sentence of the section and substitute with the following: When first approved by the AHJ, systems designed by a licensed plumbing contractor or registered design professional shall be permitted to use approved pressure relief valves in lieu of expansion tanks provided such relief valves have a maximum pressure relief set of 100psi (689kPa) or less.

B. Section 609.8.3 Hot-Water Recirculating Pumps. Delete this section of the UPC and see 14.7.9 NMAC.

C. Section 612.0 Residential fire sprinkler systems. Delete this section of the UPC and substitute with the following: When a multipurpose fire sprinkler system is installed that provides potable water to both fire sprinklers and plumbing fixtures, the potable water lines shall be installed in accordance with 14.8.2.15 NMAC, the fire sprinklers shall be installed in accordance with local fire department regulations.

[14.8.2.15 NMAC - Rp, 14.8.2.15 NMAC, 08/01/2026]

14.8.2.16 CHAPTER 7 SANITARY DRAINAGE PART I - DRAINAGE SYSTEMS: See this chapter of the UPC except as provided below.

A. Section 704.0 Fixture connections (drainage). See this section of the UPC except as provided below. **Section 704.3 Commercial Sinks.** Delete this section of the UPC and substitute with the following: Pot sinks, scullery sinks, dishwashing sinks, silverware sinks, commercial dishwashing machines, silverware washing machines, and other similar fixtures shall not be connected directly to the drainage system. Such equipment or fixtures shall be drained by means of indirect waste pipes. Food waste disposal units shall be connected directly to the drainage system. A floor drain shall be provided adjacent to the disposal unit, and the disposal unit shall be connected on the sewer side of the floor drain trap, and there shall be no other drainage line connected between the floor drain waste connection and the disposal unit drain. The floor drain shall be trapped and vented as required in this code.

B. Section 712.1 Media. See this section of the UPC except add the following text to the end. When testing during weather conditions that could result in damage to piping, adequate provisions shall be made to protect such piping from freezing.

[14.8.2.16 NMAC - Rp, 14.8.2.16 NMAC, 08/01/2026]

14.8.2.17 CHAPTER 7 SANITARY DRAINAGE PART II - BUILDING SEWERS: See this chapter of the UPC.

[14.8.2.17 NMAC - Rp, 14.8.2.17 NMAC, 08/01/2026]

14.8.2.18 CHAPTER 8 INDIRECT WASTES: See this chapter of the UPC.

[14.8.2.18 NMAC - Rp, 14.8.2.18 NMAC, 08/01/2026]

14.8.2.19 CHAPTER 9 VENTS: See this chapter of the UPC except as provided below. **Section 906.1 Roof Termination.** See this section of the UPC and add the following to the end of the section: **Exception:** When first approved by the authority having jurisdiction, a fixture or fixture branch may be permitted to be vented using an approved air admittance valve (AAV) in accordance with its listing when conventional venting termination methods are not available.

[14.8.2.19 NMAC - Rp, 14.8.2.19 NMAC, 08/01/2026]

14.8.2.20 CHAPTER 10 TRAPS AND INTERCEPTORS: See this chapter of the UPC except as provided below. **Section 1014.3.5 Construction requirements.** See this section of the UPC except delete the last sentence of the section and substitute with the following: A sample box shall be located at the outlet end of gravity grease interceptors to provide access for the authority having jurisdiction to periodically sample effluent quality.

[14.8.2.20 NMAC - Rp, 14.8.2.20 NMAC, 08/01/2026]

14.8.2.21 CHAPTER 11 STORM DRAINAGE: See this chapter of the UPC except as provided below. **Section 1101.6 Subsoil drains.** Delete the first sentence of this section and substitute with the following: Subsoil drains shall be required in accordance with 14.7.2 or 14.7.3 NMAC.

[14.8.2.21 NMAC - Rp, 14.8.2.21 NMAC, 08/01/2026]

14.8.2.22 CHAPTER 12 FUEL GAS PIPING: See this chapter of the UPC except as provided below.

A. Section 1204.2 Gas Supplier. Delete this section of the UPC and substitute with the following: A copy of certificate of such final piping inspection may be provided to the serving gas supplier supplying gas to the premises.

B. Section 1208.5.2.3 Copper and Copper Alloy Pipe. Delete this section of the UPC and substitute with the following: Copper and copper alloy pipe shall not be used on natural gas piping systems. Copper and copper alloy piping systems used in accordance with 19.15.40 NMAC shall be labeled "LP GAS PIPING SYSTEM" on yellow background with black lettering and shall be no less than ½" high lettering and shall be affixed at intervals of 5ft.

C. Section 1208.5.3.3 Copper and Copper Alloy Tubing. Delete this section of the UPC and substitute with the following: Copper and copper alloy pipe shall not be used on natural gas piping systems. Copper and copper alloy piping systems used in accordance with 19.15.40 NMAC shall be labeled "LP GAS PIPING SYSTEM" on yellow background with black lettering and shall be no less than ½" high lettering and shall be affixed at intervals of 5ft.

D. Section 1208.6 Gas Meters. See this section of the UPC except as provided below. **Section 1208.6.2 Supports.** See this section of the UPC except delete the following sentence: Where flexible connectors are

used to connect a gas meter to downstream piping at mobile homes in mobile home parks, the meter shall be supported by a post or bracket placed in a firm footing or by other means providing equivalent support.

E. Section 1208.15 Pressure Regulator and Pressure Control Venting. See this section of the UPC except delete subsection (5) and substitute with the following: Vents shall terminate not less than 3 feet (914 mm) from a possible source of ignition, make up air intake, or building intake.

F. Section 1210.9.3 Emergency shutoff valves. See this section of the UPC except delete the last sentence and replace with the following: For purposes of isolation and safety, an additional approved gas shut off valve shall be installed downstream of the serving supplier gas meter prior to any distribution of gas into the gas piping system.

G. Section 1211.0 Electrical bonding and grounding. Delete this section of the UPC and see 14.10.4 NMAC.

H. Section 1212.0 Appliance and Equipment Connections to Building Piping. See this section of the UPC except as provided below.

(1) Section 1212.1 Connecting appliances and equipment. See this section of the UPC except delete subsection (4) and substitute with the following: A connector for outdoor gas appliances in accordance with ANSI Z21.75/CSA 6.27. Only one connector shall be used per appliance.

(2) Section 1212.11 Liquefied petroleum gas facilities and piping. Delete this section of the UPC and substitute with the following: Liquefied petroleum gas facilities shall comply with Sections 70-5-1 through 70-5-23 NMSA 1978, the LPG and CNG Act, and with 19.15.40 NMAC, liquefied petroleum gas standards.

I. 1213.3 Test pressure. See this section of the UPC except add the following exception to the end of the section: **Exception:** An existing gas piping system may be tested at a test pressure of no less than 3psi with a 5psi incremental gauge and shall be held for a length of time satisfactory to the AHJ, but in no case less than 15 minutes with no perceptible drop in pressure.

[14.8.2.22 NMAC - Rp, 14.8.2.22 NMAC, 08/01/2026]

14.8.2.23 CHAPTER 13 HEALTH CARE FACILITIES AND MEDICAL GAS AND VACUUM SYSTEMS PART I - SPECIAL REQUIREMENTS FOR HEALTH CARE FACILITIES: [RESERVED]

[14.8.2.23 NMAC - Rp, 14.8.2.23 NMAC, 05/15/2018]

14.8.2.24 CHAPTER 13 HEALTH CARE FACILITIES AND MEDICAL GAS AND VACUUM SYSTEMS: Delete this chapter of the UPC and see 14.8.4 NMAC.

[14.8.2.24 NMAC - Rp, 14.8.2.24 NMAC, 08/01/2026]

14.8.2.25 CHAPTER 14 FIRESTOP PROTECTION: See this chapter of the UPC.

[14.8.2.25 NMAC - Rp, 14.8.2.25 NMAC, 08/01/2026]

14.8.2.26 CHAPTER 15 ALTERNATE WATER SOURCES FOR NONPOTABLE APPLICATIONS: See this chapter of the UPC.

[14.8.2.26 NMAC - Rp, 14.8.2.26 NMAC, 08/01/2026]

14.8.2.27 CHAPTER 16 NONPOTABLE RAINWATER CATCHMENT SYSTEMS: See this chapter of the UPC.

[14.8.2.27 NMAC - Rp, 14.8.2.27 NMAC, 08/01/2026]

14.8.2.28 [RESERVED]

14.8.2.29 CHAPTER 17 REFERENCED STANDARDS: See this chapter of the UPC except delete NFPA-99-2021 and substitute with the following: NFPA-99-2024.

[14.8.2.29 NMAC - Rp, 14.8.2.29 NMAC, 08/01/2026]

14.8.2.30 APPENDICES: See this section of the UPC except as provided below. **Appendix E Manufactured/Mobile Home Parks and Recreational Vehicle Parks.** See this appendix except as provided below.

A. Section E301.0 Manufactured/Mobile Home Park Drainage System Connection. See this section of the UPC except as provided below. **Section E301.4 Drain Connector.** Delete this section of the UPC and see 14.12.5 NMAC.

B. Section E302.0 Manufactured/Mobile Home Park Water Supply. See this section of the UPC except as provided below.

(1) **Section E302.2.1 Connection.** Delete this section of the UPC and see 14.12.5 NMAC.

(2) **Section E302.7 Water-conditioning equipment.** Delete this section of the UPC and see 14.12.5 NMAC.

C. Section E401.0 Fuel Supply. See this section of the UPC except as provided below. **Section E401.2 Gas supply connections.** See this section of the UPC except delete the last paragraph and substitute with the following. For the installation of liquefied petroleum gas (LP-gas) storage systems, see 19.15.40 NMAC.

D. Section E403.0 Multiple Manufactured Home Site Fuel Distribution and Supply Systems. See this section of the UPC except as provided below.

(1) **Section E403.1 Manufactured home community LP-gas supply systems.** See this section of the UPC except delete the last sentence and substitute with the following. Other types of liquefied petroleum gas supply systems and the storage and handling of LP-gas shall be in accordance with 19.15.40 NMAC.

(2) **Section E403.4 Pressure.** Delete this section of the UPC and see 14.12.5 NMAC.

(3) **Section E403.10 Liquefied petroleum gas equipment.** Delete this section of the UPC and see 19.15.40 NMAC.

(4) **Section E403.11 Oil supply.** Delete this section of the UPC and see 14.12.5 NMAC.

E. Section E404.0 Fuel Supply Systems Installation. Delete this section of the UPC and see 14.12.5 NMAC.

F. Section E405.0 Manufactured Home Accessory Building Fuel Supply Systems. See this section of the UPC except as provided below. **Section E405.1 General.** Delete this section of the UPC and substitute with the following. Natural gas fuel supply systems installed in an accessory building or structure shall comply with 14.8.2 or 14.9.2 NMAC.

[14.8.2.30 NMAC - Rp, 14.8.2.30 NMAC, 08/01/2026]

HISTORY OF 14.8.2 NMAC:

Pre-NMAC History: The material in this part was derived from that previously filed with state records center and archives under:

CIC MB 68-2, 1964 New Mexico Plumbing Code, filed 1/23/1968.

CIC MB 70-8, 1970 Plumbing Code of New Mexico, filed 4/29/1970.

CIC MB 71-4, 1970 Plumbing Code of New Mexico, filed 6/8/1971.

CIC MB 74-9, 1973 Uniform Plumbing Code, filed 11/20/1974.

CIC 76-1, 1976 Uniform Plumbing Code, filed 5/4/1976.

CIC MB 80-5, 1979 Uniform Plumbing Code, filed 4/24/1980.

MB-UPC-82-1, 1982 Uniform Plumbing Code, filed 11/4/1982.

MB-UPC-85-1, 1985 Uniform Plumbing Code, filed 10/1/1985.

MB-UPC-88-1, 1988 Uniform Plumbing Code, filed 12/15/1988.

MB-UPC-91-1, 1991 Uniform Plumbing Code, filed 7/28/1992.

CIC MB 68-3, 1966 New Mexico Gas Code, filed 1/23/1968.

CIC MB 70-7, 1970 Natural Gas Code of New Mexico, filed 4/29/1970.

CIC MB 71-3, 1970 Natural Gas Code of New Mexico, filed 6/8/1971.

CIC-74-8, 1973 Uniform Mechanical Code, filed 11/20/1974.

CIC 76-4, 1976 Uniform Mechanical Code, filed 11/24/1976.

CID MB 80-3, 1979 Uniform Mechanical Code, filed 4/23/1980.

MB-UMC-82-1, 1982 Uniform Mechanical Code, filed 11/4/1982.

MB-UMC-85-1, 1985 Uniform Mechanical Code, filed 10/1/1985.

MB-UMC-88-1, 1988 Uniform Mechanical Code, filed 12/15/1988.

MB-UMC-91-1, 1991 Uniform Mechanical Code, filed 7/28/1992.

CIC 77-3, 1976 New Mexico Uniform Solar Energy Code, 2/2/1977.

CID MB-80-6, 1979 Uniform Solar Energy Code, 4/24/1980.

MB-USEC-82-1, 1982 Uniform Solar Energy Code, filed 11/4/1982.

MB-USEC-85-1, 1985 Uniform Solar Energy Code, 12/23/1985.

MB-USEC-88-1, 1988 Uniform Solar Energy Code, 12/15/1988.

MB-USEC-91-1, 1991 Uniform Solar Energy Code, 7/28/1992.

CIC-75-1, 1973 Uniform Swimming Pool Code, Section 1.7, 10/31/1975.

CIC-76-3, 1976 Uniform Swimming Pool Code, 7/27/1976.

CIC MB 80-4, 1979 Uniform Swimming Pool Code, filed 4/23/1880.
MB-USPC-82-1, 1982 Uniform Swimming Pool Code, 11/4/1982.
MB-USPS and HTC-85-1, 1985 Uniform Swimming Pool, Spa and Hot Tub Code, 12/23/1985.
MB-USPS and HTC-88-1; 1988 Uniform Swimming Pool, Spa and Hot Tub Code, 12/15/1988.
MB-USPS and HTC-91-1, 1991 Uniform Swimming Pool, Spa and Hot Tub Code, 7/28/1992.
CID-MB-NMP&M 91-1, 1991 New Mexico Plumbing and Mechanical Code, 7/7/1992.
CIC MB 68-2, 1964 New Mexico Plumbing Code, filed 1/23/1968.
CIC MB 70-8, 1970 Plumbing Code of New Mexico, filed 4/29/1970.
CIC MB 71-4, 1970 New Mexico Plumbing Code, filed 6/8/1971.
CIC 74-9, 1973 Uniform Plumbing Code, filed 11/20/1974.
CIC 76-1, 1976 Uniform Plumbing Code, filed 5/4/1976.
CIC MB 80-5, 1979 Uniform Plumbing Code, filed 4/24/1980.
MB-UPC-82-1, 1982 Uniform Plumbing Code, filed 11/4/1982.
MB-UPC-85-1, 1985 Uniform Plumbing Code, filed 10/1/1985.
MB-UPC-88-1, 1988 Uniform Plumbing Code, filed 12/15/1988.
MB-UPC-91-1, 1991 Uniform Plumbing Code, filed 7/28/1992.

History of Repealed Material:

14.8.2 NMAC, 2003 New Mexico Plumbing Code (filed 5/27/2004) repealed 1/7/2004.
14.8.2 NMAC, 2006 New Mexico Plumbing Code (filed 8/16/2007) repealed 1/28/2011.
14.8.2 NMAC, 2009 New Mexico Plumbing Code (filed 12/28/2010) repealed 6/28/2013.
14.8.2 NMAC, 2009 New Mexico Plumbing Code (filed 5/29/2013) repealed 5/01/2015.
14.8.2 NMAC, 2012 New Mexico Plumbing Code (filed 3/31/2015) repealed 05/15/2018.

Other History:

CID-MB-NMP&M 91-1, 1991 New Mexico Plumbing and Mechanical Code, (filed 7/7/1992), replaced by 14 NMAC 9.2, 1997 New Mexico Plumbing and Mechanical Code, effective 12/31/1998.
14 NMAC 9.2, 1997 New Mexico Plumbing and Mechanical Code (filed 10/30/1998) and MB-UPC-91-1, 1991 Uniform Plumbing Code, filed 7/28/1992 both replaced by 14.8.2 NMAC, 2003 New Mexico Plumbing Code, effective 7/1/2004.
14.8.2 NMAC, 2003 New Mexico Plumbing Code (filed 5/27/2004) replaced by 14.8.2 NMAC, 2006 New Mexico Plumbing Code, effective 1/1/2008.
14.8.2 NMAC, 2006 New Mexico Plumbing Code (filed 8/16/2007) replaced by 14.8.2 NMAC, 2009 New Mexico Plumbing Code, effective 1/28/2011.
14.8.2 NMAC, 2009 New Mexico Plumbing Code (filed 12/28/2010) replaced by 14.8.2 NMAC, 2009 New Mexico Plumbing Code, effective 6/28/2013.
14.8.2 NMAC, 2009 New Mexico Plumbing Code (filed 5/29/2013) replaced by 14.8.2 NMAC, 2012 New Mexico Plumbing Code, effective 5/01/2015.
14.8.2 NMAC, 2012 New Mexico Plumbing Code (filed 3/31/2015) replaced by 14.8.2 NMAC, 2015 New Mexico Plumbing Code, effective 05/15/2018.
14.8.2 NMAC, 2015 New Mexico Plumbing Code (filed 5/15/2018) replaced by 14.8.2 NMAC, 2024 New Mexico Plumbing Code, effective 08/01/2026.